

CITY OF AUSTELL, GEORGIA

Addendum 2

For

Milling and Paving Raspberry Way, Hydrangea, Scuppernong, Gladiola, Malanga Ct

ITB# 25-00001-PW

SUBJECT: Questions and Answers

Date: March 21, 2025

Q: It appears that a majority of the roads have not been topped and are roughly 1"-1.5" below the gutter. On these roads are we to mill 0.5"-1" and pave 2" so that the end result is flush with gutter or are we to mill 2" and replace with 2" of topping?

A: Correct, the roads have not been topped. You will need to mill 2 inches from top of gutter.

End of Addendum